



DHRUTI DESIGN SERVICES

208, Sai Tirumala Towers, Hyderguda, Hyderabad - 29.
Ph: (040) 30284333, 334, 335, 336. Fax : 040-30284337.
e-mail: infodhruti@gmail.com

Architects Industrial Designers
Engineers Project Managers


BARRIER FREE ENVIRONMENT CERTIFICATE

I certify that **SREE RAMA ENGINEERING COLLEGE**, Ramireddy Nagar, karakambadi road, Venkatapuram , Chittoor District, Andhra Pradesh, constructed building in the survey number 225/2B the entire campus has barrier free environment as per norms .

Building has well approach 80 feet road

Building has ramp of width 5 ft with hand rail on one side that are 80 cm beyond the top and bottom of the ramp, that are smooth, and that extend 30 cm beyond the top and bottom of the ramp. Plan of Doors Suitable for the Wheelchair Bound

All Toilet rooms have at least one toilet stall for ambulant disabled.


Ar. S. SREEDHAR REDDY
REGISTERED ARCHITECT
Regd. No: CA/2001/28517

Signature of the Architect

Name of the Architect : **Ar. S. SREEDHAR REDDY**
Registration No. : CA/2001/28517

Place : Tirupati.
Date : 03/04/2023

Divyangjan Facilities



Toilets



Wheel Chair and Ramp Facilities